

Sample Number	Material	Lab Notes	HA	Condition	Damage Potential	Friable (Y/N)	Asbestos Type-%	EPA NESHAP Category
WP-46	Remnant Parapet		31	Good	Low	N	~~8% Chrysotile~~	Cat.1
WP-47	Chimney Caulk		32	Good	Low	N	NAO	NA
WP-48	Window Flashing		33	Good	Low	N	NAO	NA
WP-49	Window Caulk		22	Good	Low	N	NAO	NA
WP-50	Flashing		34	Good	Low	N	NAO	NA
WP-51	Rolled Roof		35	Good	Low	N	NAO	NA
WP-52	Roof Sealant		36	Good	Low	N	NAO	NA
WP-53	Brick Caulk		37	Good	Low	N	NAO	NA
WP-54	Membrane Caulk		38	Good	Low	N	NAO	NA
WP-55	Remnant Flashing		39	Good	Low	N	NAO	NA
WP-56	HVAC Caulk		40	Good	Low	N	NAO	NA
WP-57	Vent Caulk		41	Good	Low	N	NAO	NA
WP-58	Remnant Flashing		42	Good	Low	N	2% Chrysotile	Cat.1
WP-59	Remnant Roof		43	Good	Low	N	3% Chrysotile	Cat.1
WP-60	Parapet		44	Good	Low	N	NAO	NA
WP-61	Flashing		45	Good	Low	N	3% Chrysotile	Cat.1
WP-62	Stucco Caulk		46	Good	Low	N	NAO	NA
WP-63	Structure Caulk		47	Good	Low	N	NAO	NA
WP-64	Stucco		48	Good	Low	N	NAO	NA
WP-65	Repair Caulk		49	Good	Low	N	NAO	NA
WP-66	Remnant Flashing		42	Good	Low	N	2% Chrysotile	Cat.1
WP-67	Remnant Flashing		42	Good	Low	N	2% Chrysotile	Cat.1
WP-68	Window Caulk		22	Good	Low	N	NAO	NA
WP-69	Door Caulk		50	Good	Low	N	NAO	NA
WP-70	Repair Caulk		49	Good	Low	N	NAO	NA
WP-71	Texture		51	Good	Low	N	NAO	NA
WP-72	Texture		51	Good	Low	N	NAO	NA
WP-73	Texture		51	Good	Low	N	NAO	NA
WP-74	Shingle		42	Good	Low	N	NAO	NA
WP-75	HVAC Mastic		43	Good	Low	N	NAO	NA
WP-76	HVAC Damper		23	Good	Low	N	NAO	NA
WP-77	Stucco		48	Good	Low	N	NAO	NA
WP-78	HVAC Mastic		43	Good	Low	N	NAO	NA
WP-79	Door Caulk		50	Good	Low	N	NAO	NA
WP-80	Stucco		48	Good	Low	N	NAO	NA
WP-81	Window Caulk		22	Good	Low	N	NAO	NA
WP-82	Door Caulk		50	Good	Low	N	NAO	NA
WP-83	Gap Caulk		52	Good	Low	N	NAO	NA
WP-84	Stucco		48	Good	Low	N	NAO	NA
WP-85	HVAC Caulk		40	Good	Low	N	NAO	NA
WP-86	Concrete Coat		53	Good	Low	N	NAO	NA
WP-87	Concrete Coat		53	Good	Low	N	NAO	NA
WP-88	Pen Repair		54	Good	Low	N	NAO	NA
WP-89	Window Glaze		55	Good	Low	N	NAO	NA

WB = Wallboard
 JC = Joint Compound
 M = Mastic
 FT = Floor Tile

CT = Ceiling Tile
 CG = Carpet Glue
 Pen = Penetration